



HINGHAM FIRE DEPARTMENT FIRE PREVENTION

210 Central Street
Hingham, MA 02043

Lieutenant Christopher DiNapoli
Fire Marshal



March 4, 2021

Members of the Planning Board,

The fire dept. has reviewed the plans submitted for a proposed Definitive Subdivision at 101 Gardner St and offer the following comments.

Hydrant Bylaw Residential:

Hydrant Bylaw Article 32 Section 9: For residential properties a hydrant must be located within 800 feet of the new structure(s). This is measured over approved drivable service not as the crow flies.

For new roadways for any roadway requested to not be built to the current standard an engineer's report must be provided showing the roadway can support 85,000 lbs. the weight of our largest apparatus.

Any roadway or driveway in excess of 150 feet is required to provide a turn around that will allow a 10 wheel platform aerial device to turn around

Access driveways and roadways must be able to accommodate A 10 wheel tower fire apparatus. Turning templates are available on the Planning Board site through the town website.

Grades may not exceed 10 degrees

These represent our comments at this time. As the project develops we may offer further comments.

Respectfully,

Lieutenant Chris DiNapoli
Fire Marshal, Town of Hingham