

**CCR ASSOCIATES**  
Engineers & Surveyors

Suite 203A, 49 Pleasant Street, S. Weymouth, MA 02190 Phone (617) 335-6176  
Fax (617) 340-1889

January 31, 1998.

Attention:-  
Hingham Board of Health,  
Bruce T. Capman Executive Director.

*WILLIAM BLAKE 781-749-7512*

Re / Soil Evaluation at 163 Prospect Street, Hingham.

I performed a soil evaluation at 163 Prospect Street, Hingham on 1-31-98.

I did not find water, seeping water or mottling at 12' depth (excavation limit of backhoe).

I estimate High Water table is at least 10' below the bottom of the Leaching Pits based on soil type and a drop in grade of approx. 20' between the septic system area and existing grade at the rear of the property.

Attached are completed Soil Evaluation Forms.

Sincerely,

*Patrick Roseingrave*

Patrick Roseingrave.  
Registered Professional Engineer.

