



## HINGHAM FIRE DEPARTMENT FIRE PREVENTION

210 Central Street  
Hingham, MA 02043

Lieutenant Christopher DiNapoli  
Fire Marshal

September 16, 2021

Members of the Planning Board,

The Fire Dept. has received and reviewed the proposed project for 213-215 Cushing St. After review of the submittal we offer the following comments.

- 1) A hydrant would be required for the development as the far end of the project is over a 1000 feet from the closest hydrant. The town's hydrant bylaw requires hydrant no further than 800 feet for a residential property. Hydrant location can be discussed with this office prior to installation.

The turning radiuses provided appear to be appropriate. These represent our comments at this time. As the project continues to develop we may offer further comment after review.

Respectfully,

Lieutenant Chris DiNapoli  
Fire Marshal, Town of Hingham