




HINGHAM FIRE DEPARTMENT FIRE PREVENTION

210 Central Street
Hingham, MA 02043



Lieutenant Christopher DiNapoli
Fire Marshal

November 8, 2021

Member of the Planning Board,

In regards to the proposed project at 36 East St/0 Rockwood Rd, the fire dept. has reviewed the plans and we offer the following comments.

- The hydrant by-law is satisfied as it appears the new structure will be approx. 617 +/- feet from the closest hydrant.
- The new driveway however must be widened to 14 feet to satisfy 527 CMR 1.00 the Massachusetts Comprehensive Fire Safety Code.

These are our comments at this time. As the project continues to develop we may offer further comments in the future.

Respectfully,

Lieutenant Chris DiNapoli
Fire Marshal, Town of Hingham