




HINGHAM FIRE DEPARTMENT FIRE PREVENTION

210 Central Street
Hingham, MA 02043



Lieutenant Christopher DiNapoli
Fire Marshal

November 10, 2021

Member of the Planning Board,

In regards to my previous comments related to the proposed project at 36 East St/0Rockwood Rd. Driveway access must be 14' wide from point of entry from the main roadway. In other words 14' shall be maintained from East St to the dwelling, not just on the 36 East St property. I hope this clarifies any confusion related to my previous comments.

Respectfully,

Lieutenant Chris DiNapoli
Fire Marshal, Town of Hingham