




HINGHAM FIRE DEPARTMENT FIRE PREVENTION

210 Central Street
Hingham, MA 02043



Lieutenant Christopher DiNapoli
Fire Marshal

December 10, 2021

Members of the Planning Board,

This letter is to clarify earlier letters regarding the property located at 36 East St/0 Rockwood Rd. To receive relief from the code in regards to the driveway width all livable/habitable spaces must be sprinklered. This is to include both new construction as well as existing structures on the property such as the proposed home office. Should you have any questions please feel free to reach out to me.

Respectfully,

Lieutenant Chris DiNapoli
Fire Marshal, Town of Hingham