

Savage-Dunham, Mary

From: Sarni, Susan
Sent: Thursday, February 21, 2019 12:41 PM
To: Savage-Dunham, Mary
Subject: 315 Lincoln St

Hi Mary,

I reviewed the plans online for 315 Lincoln St and have the following comments:

- Will this be slab construction or a full foundation?
- Under the FOG regulations we will require a 1500 gallon external grease trap.
- All new food establishments are required to submit paper plans to scale with cuts sheets along with the menu for a review.

Thanks,
Susan



Town of Hingham Massachusetts

Susan Sarni, MPH

Executive Health Officer
Town of Hingham
210 Central Street
Hingham, MA 02043
Voice: (781) 741-1466
Fax: (781) 804 2373
sarnis@hingham-ma.gov
www.hingham-ma.gov