

Savage-Dunham, Mary

From: Dempsey, Stephen
Sent: Tuesday, May 14, 2019 12:24 PM
To: Savage-Dunham, Mary
Subject: RE: Bank Ave project

Hi Mary,

After review of the draft plan sent to me by Cavanero Consulting on Friday, May 10, it is apparent that the proposed sewer service to be installed requires the existing garage to be demolished in order to install a new manhole and connect to an existing manhole on the property. The existing sewer service must be cut and capped by a licensed drainlayer prior to the demolition. A video inspection of the existing service must be performed prior to the connection to ensure the integrity of the service is sound. All permits and fees must be complete and paid in full prior to the work being performed. The installation must be in compliance with the Sewer Commission's current Rules and Regulations. Barring something unforeseen, the Sewer Department will approve the connection.

Please feel free to contact me with any further discussion.

Stephen Dempsey
Sewer Supervisor
Hingham Sewer Department
25 Bare Cove Park Drive
Hingham, MA 02043
Office: (781) 741-1430
Fax: (781) 741-1432
dempseys@hingham-ma.gov
www.hingham-ma.gov

-----Original Message-----

From: Savage-Dunham, Mary
Sent: Tuesday, May 14, 2019 6:46 AM
To: Dempsey, Stephen <dempseys@hingham-ma.gov>
Subject: Bank Ave project

Good morning

This project is on May 21 PB agenda. If you have any requirements or conditions for approval please advise.

Mary Savage Dunham
Director of Community Planning
Town of Hingham
781-561-6304 (c)
781-741-1419 (o)

Sent from my iPhone