

## Savage-Dunham, Mary

---

**From:** Sarni, Susan  
**Sent:** Wednesday, June 12, 2019 9:45 AM  
**To:** Savage-Dunham, Mary  
**Cc:** Nee, Betty  
**Subject:** 99 Derby St

Hi Mary,

I reviewed the comments and calculations for the septic system located at 99 Derby St. I have some concerns which I have listed below.

- The system is currently designed for office space. The school would be a change of use under Title 5 an additional flow. I do not agree with Scenario 1 that the school is an office.
- Scenario 2, how can a school operate from 9-3 without a cafeteria? If there is any kind of food served the gpd would be over the design capacity. Will there be any kind of kitchen and what is the use?

The very minimum I would request a Title 5 Inspection as it is a change of use along with a new soil evaluation to determine groundwater. The system was built in 1990. I need more documentation regarding food for the students.

-Susan



Town of Hingham Massachusetts

**Susan Sarni, MPH**  
Executive Health Officer  
Town of Hingham  
210 Central Street  
Hingham, MA 02043  
Voice: (781) 741-1466  
Fax: (781) 804 2373  
[sarnis@hingham-ma.gov](mailto:sarnis@hingham-ma.gov)  
[www.hingham-ma.gov](http://www.hingham-ma.gov)