



HINGHAM FIRE DEPARTMENT FIRE PREVENTION

210 Central Street
Hingham, MA 02043

Lieutenant Christopher DiNapoli
Fire Marshal

July 24, 2019

Members of the Planning Board,

The fire dept. has reviewed the proposed plans submitted for 156 Chief Justice Cushing Highway. At this time we offer the following comments.

- 1) As per the Town of Hingham By-Laws Article 32 Section 9 a fire hydrant is required within 800 feet of a residential property.
- 2) Access roads and driveways must be able to accommodate our 10 wheel platform fire apparatus. Turning templates are available from this office or the Planning Board.
- 3) Any roadway or driveway in excess of 150 feet is required to provide a turnaround for the above mentioned fire apparatus.

These are comments at this time. As the project continues to develop this office may offer further comments.

Respectfully,

Lieutenant Chris DiNapoli
Fire Marshal, Town of Hingham